

CERTIFICATE OF COMPLIANCE

Certificate Number E321126
Report Reference E321126-20200121
Date 2020-November-17

Issued to: TDK (Zhuhai FTZ) Co., Ltd.
No. 4 Lianfeng Road, Xiangzhou District
ZhuhaiGuangdong 519030 CN

**This is to certify that
representative samples of**

SURGE-PROTECTIVE DEVICES - COMPONENT
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

Standard(s) for Safety:

UL 1449- Surge Protective Devices

CSA C22.2 No. 269.4-17- Surge protective devices – Type 4 - Component Assemblies

Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E321126
Report Reference E321126-20200121
Date 2020-November-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Cat. No. MT30, followed by K or SA, followed by followed by 150, 230, 275, 320, 350, 385, 420, 440, 460, 510, 550, 625, 680 or 750, followed by M4, maybe follow by suffix K1 thru K99

MT30(O)150M4(Q)@
MT30(O)230M4(Q)@
MT30(O)275M4(Q)@
MT30(O)320M4(Q)@
MT30(O)350M4(Q)@
MT30(O)385M4(Q)@
MT30(O)420M4(Q)@
MT30(O)440M4(Q)@
MT30(O)460M4(Q)@
MT30(O)510M4(Q)@
MT30(O)550M4(Q)@
MT30(O)625M4(Q)@
MT30(O)680M4(Q)@
MT30(O)750M4(Q)@

(O) - can be K or SA.

(Q) - can be K1 thru K99.

@ - Rated for used in altitude up to 5000m.

Status/Alarm Circuit/Form C Contacts: Class 2



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>