

SIOV metal oxide varistors

Climatic conditions

Date: January 2018

© EPCOS AG 2018. Reproduction, publication and dissemination of this publication, enclosures hereto and the information contained therein without EPCOS' prior express consent is prohibited.


EPCOS AG is a TDK Group Company.

Climatic conditions

Climatic category

Varistors are assigned to climatic categories according to the climatic conditions under which they have been tested.

The IEC climatic category is specified for all varistors in the data sheets. In accordance with IEC 60068-1 (Appendix A) the climatic category is made up of three sets of digits, which are decoded as shown in the following example:



- 1st group: Lower category temperature (temperature limit) denoting the test temperature for test A (cold) in accordance with IEC 60068-2-1.
- 2nd group: Upper category temperature (temperature limit) denoting the test temperature for test B (dry heat) in accordance with IEC 60068-2-2.
- 3rd group: Number of days, the duration of test Cab (damp heat, steady state) at a relative humidity of 93% +2/-3% and an ambient temperature of 40 °C, in accordance with IEC 60068-2-78.