

SIOV metal oxide varistors

Climatic conditions


Date: April 2026

Climatic conditions

Climatic category

Varistors are assigned to climatic categories according to the climatic conditions under which they have been tested.

The IEC climatic category is specified for all varistors in the data sheets. In accordance with IEC 60068-1 (Appendix A) the climatic category is made up of three sets of digits, which are decoded as shown in the following example:



- 1st group: Lower category temperature (temperature limit) denoting the test temperature for test A (cold) in accordance with IEC 60068-2-1.
- 2nd group: Upper category temperature (temperature limit) denoting the test temperature for test B (dry heat) in accordance with IEC 60068-2-2.
- 3rd group: Number of days, the duration of test Cab (damp heat, steady state) at a relative humidity of 93% +2/-3% and an ambient temperature of 40 °C, in accordance with IEC 60068-2-78.